

Distributed Heating Stations Supplied by Excess Heat


MONITORING & EVALUATION



"The project has received funding from the European Union's Horizon 2020 research and innovation programme under grant agreement n° 767799-COOL DH- H2020-EE-2016-2017/H2020-EE-2017-RIA-1A"

Monitoring & Evaluation of COOL DH

- Energy performance (Losses, COP, Temp.)
- Environmental impacts (CO2 Emissions)
- Economic analysis
- Social studies (Experiences, Feedback)
- ***Preliminary Results on this presentation***



Lund – Brunnshög area


1. Xplorion Building
2. Recovery of Excess Heat at MAX IV
3. New LTDH network
4. Heat recovery pipe
5. Prosumer

Max IV
Research facility

Motel

ESS
Research facility

Xplorion
Residential building



Interesting Findings

- Proper installation: Sensor adjustment
- Necessary measures: External access to heat units
- Local conditions: Using heat pumps



1. Xplorion


- A multi-storey and passive house building
- Gross area: 4374 m²
- Heated area: 3606 m²
- Comprising 54 flats, bike garage, laundry, lokal room, and a restaurant



The project has received funding from the European Union's Horizon 2020 research and innovation programme under the grant agreement n° 767799 - COOL DH - H2020-EE-2016-2017/H2020-EE-2017-RIA-IA

1. Xplorion – Innovations


- Booster HP to simulate ULTDH demo
- LTDH (60/30°C) + ULTDH (45/25°C)



Simplified sketch of the hot water topping system in the basement


1. Xplorion – Innovations

- 3-pipe system




1. Xplorion – Innovations

- Flat stations with Micro Heat Exchangers (Heating units)




1. Xplorion – Distribution Temperatures

- Low supply temperature: **60°C**
- Return temperature decreased from **55°C** to around **30°C**
- Currently: 60/30°C
- U-LTDH mode



1. Xplorion – Sensor adjustment for T_{ret}

- Difficulty: Internal access to FS




1. Xplorion – Heat Demand

• 2021 Data

○ Heat supply = 237 MWh

○ Heat use = 187 MWh

○ Pipe losses = 50 MWh (21%)



1. Xplorion – Pipe losses

- **2021**

- Annual pipe losses: **13.9 kWh/m²** (Ref.: 10.2 kWh/m²)
 - High return temp. → Fixed
 - Not 100% insulation
 - 1 out of service heat meter → Fixed

- **2022**

- Pipe losses decreased by % 20 – 25 →
- Estimation: Pipe losses **15%**
- Annual pipe losses = **10.3 kWh/m²**



1. Xplorion – Environmental Impacts

- Reference values: *Heating: 11.4 kg/MWh ; Cooling: 1.3 kg/MWh ; Electricity: 41.9 kg/MWh*
- **CO₂ emissions in April 2022:**
- $(1.966 \times 41.9) - (17.25 \text{ MWh} \times 11.4 \text{ kg/MWh}) = - \mathbf{114 \text{ kg}}$
- 2022 Estimation in CO₂ reduction: **1.3 tons**
- **If it would be in Høje-Taastrup**
- $(1.966 \times 161.9) - (17.25 \text{ MWh} \times 54.5 \text{ kg/MWh}) = - \mathbf{622 \text{ kg}}$
- **Primary Energy Saving (PES) in April 2022: 13 MWh**
- 2022 Estimation: **153 MWh**



1. Xplorion – Economic data

- Baseline Scenario (LTDH) = € 93,733
- Booster HP Scenario (ULTDH) = € 142,961
- Increased Investment = **€ 49,228**
- Annual Saving = Not enough data
- PB year = ?




2. Recovery of Excess Heat at MAX IV

- Purpose: Supply cooling demand of the facility and at the same time recovering the surplus heat from low temperature heat source to provide local conventional DH + LTDH networks
- Capacity: 5.8 MW for the heating and 5.2 MW for the cooling circuit
- DHS is entirely supplied by renewable electricity by a CHP




2. MAX IV – Energy Balance

- Total Heating Production = 34.3 GWh
- Heat for LTDH network = 4.5 GWh
- Cooling Production = 22.8 GWh
- Electricity Consumption = 11.5 GWh



2. MAX IV – Performance of HP


- Average $COP_h = 2.9$
- Average $COP_c = 2.0$
- Average total COP = 4.9



The project has received funding from the European Union's Horizon 2020 research and innovation programme under the grant agreement n° 767799 - COOL DH - H2020-EE-2016-2017/H2020-EE-2017-RIA-IA

2. MAX IV – Distribution Temperatures

- DH 75/40 °C → 65/35 °C
- LTDH 67/50°C
 - (Developing network)



The project has received funding from the European Union's Horizon 2020 research and innovation programme under the grant agreement n° 767799 - COOL DH - H2020-EE-2016-2017/H2020-EE-2017-RIA-IA

2. MAX IV – Environmental Impacts

- **CO₂ emissions since Jan. 2021:**
 - $(11500 \times 41.9) - (32600 \text{ MWh} \times 11.4 \text{ kg/MWh}) - (22800 \times 1.3) = + \textbf{81 tons!}$
 - (KR has Green cert.= - 401 tons)
- **If it would be in Høje-Taastrup**
 - $(11500 \times 161.9) - (32600 \text{ MWh} \times 54.5 \text{ kg/MWh}) - (22800 \times 80.75) = - \textbf{1756 tons}$
- **Natural Gas:** $32600 \text{ MWh} \times 202 \text{ kg/MWh} = + \textbf{6585 tons}$
- **PES since Jan. 2021:**
 - Heating bonus method: 32.6 GWh
 - Allocation method: **18.3 GWh**



2. MAX IV – Economic data

- Total cost in project: **€ 305,000**
- Heat for LTDH cost: $2900 \text{ MWh} \times 30 \text{ €/MWh} = \text{€ } 87,000$
- Electricity cost: $800 \text{ (Allocated to LTDH)} \times 77 = \text{€ } 61,600$
- Annual saving: $87000 - 61600 = \text{€ } 25,400$
- Payback = $305,000 / 25,400 = \textbf{12 years}$
- Heating bonus method: $\text{PB} = 305,000 / 87,000 = \textbf{3.5 years}$



COOL DH Team at LTH/LU



Ali Moallemi

ali.moallemi@energy.lth.se



Kerstin Sernhed

kerstin.sernhed@energy.lth.se



Henrik Gadd

henrik.gadd@hh.se

Thanks For Your Attention



The project has received funding from the European Union's Horizon 2020 research and innovation programme under the grant agreement n° 767799 - COOL DH - H2020-EE-2016-2017/H2020-EE-2017-RIA-IA